

Date: **November 14, 2023**

Owner: **Victor Elementary School District**  
143 E. First Street  
Perris, CA 90720

Architect: **Westgroup Designs**  
19900 MacArthur Blvd., Suite 1000  
Irvine, CA 92612

Project: HVAC replacement project, Group 1

The clarifications, modifications, changes, additions, and/or deletions contained herein shall be incorporated within the bid documents for the project. Such information shall take precedence over that previously published.

### **BID ADDENDUM 3**

Please be informed of the following Bid Addendum items:

#### **GENERAL**

1. *PRE-BID RFI RESPONSES*

**See 'Exhibit C' attached.**

---

#### **ATTACHMENTS:**

- EXHIBIT C\_231114  
(Exhibit 'C', date 11.14.2023)

**END**

Sincerely,



**Michael Cecconi, LEED AP | Senior Associate, Project Architect**



**BID # 23-002**

HVAC IMPROVEMENTS GROUP 1 – 4 SITES  
VICTOR ELEMENTARY SCHOOL DISTRICT  
VICTORVILLE, CA

November 14<sup>th</sup>, 2023

**EXHIBIT C - ADDENDUM – 03**

**SPECIFICATIONS**

ITEM NO. 1      PROJECT MANUAL, SPECIFICATION SECTION- 001116 NOTICE INVITING BIDS

A. The bid deadline remains 02:00:00 o'clock PM. on the **17<sup>th</sup> day of November 2023**. The location for receipt of Bids remains the District Office for Victor Elementary School District, located at 12219 2<sup>nd</sup> Ave., Victorville, CA 92395.

**REQUESTS FOR CLARIFICATIONS**

ITEM NO. 2      Question: At Del Rey, Detail 7/Sheet M0-2.1 states to have piping set on channel strut with pipe clamp. Please provide clarification on whether the support is to be pressure treated wood or Durablock type product with channel embedded.

Response: All Bidders

Bid Package contractors shall provide Durablock type product with channel embedded where specified.

ITEM NO. 3      Question: At Del Rey, Details 8 & 9/Sheet M0-2.1 notes to provide a smoke detector for units moving more than 2000 CFM, please provide clarification on whether this requirement is for both supply and return, or just the supply.

Response: BP-01 – HVAC

Smoke detectors shall be located in the main supply-air duct.

END OF ADDENDUM 03